



Kerala Co-operative Milk Marketing Federation Limited

Cattle Feed Plant, Malampuzha, Palakkad - 678651

Phone: 0491-2816316/317 Website: www.milma.com,

E-mail: cfmprod@milma.com GST: 32AAAK5375M6ZB(PAN: AAAAK5375M)

CFP-M/PROD/107/DG/2026/4074

23.07.2026

QUOTATION NOTICE

Sub: Inviting sealed price quotations for "Installation of diesel generator changeover arrangement for essential loads during shutdown maintenance periods" Reg:-

Kerala Co-Operative Milk Marketing Federation Limited (MILMA), Cattle Feed Plant, Malampuzha, Palakkad - 678651 invites your sealed competitive price quotations for Installation of diesel generator changeover arrangement for essential loads during shutdown maintenance periods as per the Annexure enclosed herewith. The bidding shall be subjected and binding to the following terms and conditions.

I. General Terms & Conditions:

- 1. PRICE BASIS:** All prices must be quoted as FOR site basis, including all Taxes cum duties and freight, packing, forwarding, transit risk insurance, loading, miscellaneous incidental charges for the safe delivery of the items at our end and labor charge for the entire construction. Nothing extra will be paid on this account for any reason.
- 2. PRICE VALIDITY :** The competitive price offered shall remain valid for 3 Months for acceptance from the date of your offer. Once you have secured the contract for the amount you quoted any deviation in your price validity not allowed until the work as per the contract is completed.
- 3. GUARANTEE PERIOD:** The contractor must guarantee for performance and Quality of the work for a minimum period and shall be mentioned in the quotation. The contractor shall rectify defect if any noticed in works due to bad workmanship at free of cost on guarantee period.
- 4. PAYMENT MODE:** 90% payment will be released against invoice within 30 days after satisfactorily completion of entire jobs. Advance payment will not be entertained. Our bankers are SBI Palakkad & Canara bank Malampuzha. Remaining 10% shall be released upon successful completion of guarantee period.
- 5. LIQUIDATED DAMAGE
CLAUSE:** In case the work is not completed within the stipulated time period, liquidated damages @1% of total work order value per week will be charged for the items so delayed subject to a maximum of 5% of the total value.

II. Specific Terms & Conditions:

1. **Essential Documents:** The bidder shall furnish the following details/documents (as copy) for becoming eligible to technically qualify in the bid
 - a Name of the Bidder / Enterprise entitled to supply
 - b Company Registration certificate
 - c Address proof of the Enterprise
 - d Valid ID proof of the Bidder (such as Adhar)
 - e PAN copy
 - d. GST registration certificate copy (if registered)
2. All the works shall be carried out as per the directions and supervision of our plant Engineer.
3. The Contractor shall provide all the materials required for the worksite before commencement of work. The Contractor shall supply tools and tackles required for the works. Nothing will be arranged from our end.
4. The contractor shall arrange for all compliance to the ESI/PF rules in force. Cattle Feed Plant shall not be liable for any benefits/compensation to the workers engaged by the contractor, in the event of accidents/mishaps etc. during execution of work. The contractor shall provide suitable safety measures to their workmen at the work spot. The contractor or his workmen shall not interfere in any activity of the Plant and/or cause any damages to buildings/property. The entry of all such workmen will be on the basis of gate pass, which will have to be arranged by the Contractor prior to starting the work. In the event of any damage to Milma Cattle Feed Plant's property, due to the Contractor, the Contractor alone shall be liable.
5. Statutory deductions related to Income tax, ESI, EPF and other applicable statutory deductions will be affected while settling bills.
6. The entire works shall be completed within one month from the date receipt of the work order. And once the work begins the entire works shall be completed within 7 days.
7. All safety measures related to the job order shall be arranged by the Contractor. Work permit shall be taken by the Contractor before the commencement of work. All risk shall be covered by Contractor as per norms.
8. Any deviations in the price quote, validity period, guarantee period, payment mode from as stipulated above shall be clearly specified.
9. Rates shall be quoted only in Indian Rupees. Rates shall be fixed during the entire validity period and Price quotations with dynamic pricing and including any other conditional clauses will be summarily rejected.
10. **Right of Acceptance:** The undersigned reserves the right to accept the offer either in full or in part, or to reject it entirely, without assigning any reason.
11. **Bid Opening:** Only sealed quotations received by postal are valid and considered for evaluation. Open quotations submitted in hand or sent by email will be treated non-responsive and will be totally rejected. Hence the bidders are requested to send their valuable sealed quotations by postal well in advance before the date of opening. Sealed quotations shall reach our office on or before **3:00 PM of 31.07.2026** and the received quotations will be opened on the same day at **3.30 PM** in the presence of bidders if any available. Quotations received after 3:00 PM will be rejected.
12. **Bidder Confirmation:** Technically qualified bids will only be considered for financial evaluation. Price bids will be assessed in accordance with the Least Cost Based Selection System. All the bids will be evaluated on the basis of the eligibility criteria through verification of all the essential documents submitted along with the terms & conditions complied by bidder. Though the L1 bidder will be the preferred bidder, simply quoting of

lowest rate does not confer any right for selection of the bidder at the rate quoted. KCMMF reserves the right to confirm and finalize the bidder. Quoting of same rates (L1 only) by more than one bidder could be construed as an exceptional circumstance. In such cases, all the bidders who have quoted the same lowest rates shall be called for and one more chance will be given for on spot quoting if bidders are present or negotiated quote may be collected via mail with a closing time for rate finalization. If the negotiated quotes are still the same, KCMMF reserves the right to award the purchase order to that party at its discretion subject to the reputation/performance of the party based on their business volume, providing extended guarantee period, prompt service, , customer satisfaction etc. or to cancel the tender for proceeding with re-tender.

13. **Experience:-** The bidder should be in the same business for a minimum period of one years at the time of bid opening. Bidder should posses the Electrical inspectorate approved contract license and copy of the same shall be submitted along with the quotation.

14. **Details of WORK**

Details of WORK with specifications and quantity are as mentioned in the **Annexure** enclosed herewith and also available at our official website <https://www.milma.com/tender/tendernotices>


15. **Submission Details:**


The quotation must be submitted in a sealed cover clearly super scribed: **"Quotation For Installation of diesel generator changeover arrangement for essential loads during shutdown maintenance periods"** and shall be addressed to:

**THE MANAGER
MILMA CATTLE FEED PLANT
MALAMPUZHA
PALAKKAD – 678651**

16. Interested bidders may visit the site & communicate with our officials through the phone numbers mentioned above on all working days between 9 AM to 5 PM with prior intimation, before bid submission.




MANAGER



Copy to: FO, Office File

To be displayed/published at

1. All Notice Boards, CFPM
2. Panchayath Office, Malampuzha
3. ITI, Manthakkad
4. Village Office, Malampuzha
5. Milma website
6. Kalleppully diary

Encl: Annexure – Details of Work with specifications.



Kerala Co-operative Milk Marketing Federation Limited

Cattle Feed Plant, Malampuzha, Palakkad - 678651

Phone: 0491-2816316/317 Website: www.milma.com,

E-mail: cfmprod@milma.com GST: 32AAAK5375M6ZB(PAN: AAAAK5375M)

QUOTATION SUBMISSION FORM

QUOTATION NO: CFP-M/PROD/107/DG/2026/

dtd 23.07.2026

Date & Time of Opening: 31.07.2026 at 3.30.pm

1	Name & Address of the Quotationer.	
2	Phone Number(Mob)/ Land Phone Number & e-mail	
3	Aadhaar Card Number (linked with PAN): (Documents to be enclosed)	
4	GST Registration Number (Documents to be enclosed)	
5	PAN card Registration Number (Documents to be enclosed)	
6	License Issued from Electrical Inspectorate	

ANNEXURE

(List of Items with description, specifications, Quantity)

Technical Requirements & Specification

Scope of Work

The work comprises design, supply, installation, testing and commissioning of a DG Changeover Arrangement for feeding essential loads from a single 500 kVA Diesel Generator during scheduled plant shutdown maintenance periods and during KSEB power failures. Contractor responsible for the complete process starting from **Design, Approval, Execution, Inspection and finally till obtaining Safety Certificate.**

Existing Condition : At present, essential loads such as lighting circuits, fan loads, FPG godown conveyors, weigh bridge and other critical service loads are distributed between the 500 kVA and 650 kVA Diesel Generators. Consequently, during shutdown maintenance periods and power failure conditions, both DG sets are required to be operated for supplying these loads, resulting in unnecessary fuel consumption and operating costs.

The objective of this work is to rearrange the power distribution system and provide a suitable changeover arrangement so that all identified essential loads can be supplied through a single 500 kVA DG set during maintenance shutdown periods and emergency power failure conditions

Technical Specification

- Supply and installation of one Multi-Cubicle Type Fully Compartmentalized Switch Board (SSB-1A) fabricated from 16 SWG CRCA sheet steel.
- Panel construction shall be processed through seven-tank chemical treatment comprising degreasing, derusting and phosphating. No welding, drilling or fabrication work shall be carried out after phosphating treatment.
- The panel shall be fully compartmentalized with uniform height and depth and shall be powder coated after fabrication and treatment.
- Busbars shall be of electrolytic grade aluminium with suitable insulation and supports.
- Switchgear Configuration
- Incoming: 250A Changeover Switch – 1 No.
- Outgoing Feeders:
 1. 160A TPN SFU – 1 No.
 2. 100A TPN SFU – 3 Nos.
- Cable Works: Laying, dressing, termination, testing and commissioning of 95 sq.mm power cables for the feeders :MSB to SSB-1A, MASB-2 to SSB-1A, SSB-1A to LSB-1, SSB-1A to LSB-2, SSB-1A to LSB-3
- **Engineering and Documentation:** Contractor shall involve with the detailed site study and load assessment, Design of the proposed DG changeover scheme for essential loads, Preparation of Single Line Diagram (SLD), Preparation of panel GA drawings and cable routing drawings, wherever required, Preparation and submission of all technical documents, calculations and statutory forms required for approval, Incorporation of comments, if any, raised by the Electrical Inspectorate
- **Statutory Approval and Liaison Services:** Submission of the proposed scheme to the Electrical Inspectorate for approval, Liaison and follow-up with the Electrical Inspectorate for obtaining scheme approval, Preparation and submission of completion reports and completion certificates after execution of the work, Arranging inspection of the installation by the Electrical Inspectorate, Attending inspection and providing all necessary technical clarifications, Obtaining Safety Certificate / Energisation Approval from the Electrical Inspectorate for the completed installation, Coordination with client representatives and statutory authorities until final approval is obtained.

The arrangement shall ensure transfer of essential loads to the dedicated essential load switchboard and facilitate operation of these loads from a single 500 kVA DG set during shutdown periods.

Exclusions

- All cable glands and glanding accessories shall be provided by KCMMF.
- Earthing connection for SSB-1A shall be provided by KCMMF.
- Statutory fees and any other charges payable to the Electrical Inspectorate or other Government Authorities shall be borne by KCMMF at actual.

Price Bid Format with schedule of quantities

SI No	Description Of the work	Qty	Rate	Amount
1	Supply, installation, testing and commissioning of SSB-1A complete with 250A Changeover Switch, 160A TPN SFU (1 No.), 100A TPN SFU (3 Nos.), aluminium busbars, internal wiring, accessories and powder-coated enclosure	1 Set		
2	Laying, dressing, termination and commissioning of 95 sq.mm power cable between MSB to SSB-1A, MASB-2 to SSB-1A, SSB-1A to LSB-1, SSB-1A to LSB-2 and SSB-1A to LSB-3	1 Lot		
3	Design, preparation and submission of electrical drawings, Single Line Diagram (SLD) and statutory documents for Electrical Inspectorate approval	1 Lot		
4	Liaisoning with Electrical Inspectorate for scheme approval, including submission, follow-up and obtaining approval	1 Lot		
5	Preparation and submission of completion certificate and statutory documents, arranging Electrical Inspectorate inspection and obtaining Safety Certificate / Energisation Approval	1 Lot		
TOTAL AMOUNT				
GST				
GRAND TOTAL				

Name and signature of the Quotationer